



901 Main Street
P.O. Box 72
Geraldton, Ontario
P0T 1M0
Fax: 8078540483

November 2022

SuperiorGreenstone District School Board
Dorion Public School
RR1
Dorion, Ontario
P0T 1K0

Re: Dorion Public School Drinking Water System Annual Report

To whom it may concern:

Attached is the April 1, 2021-March 31, 2022 Annual Report for the

2021 - 2022 Annual Report

Dorion Public School Drinking Water System

November 2022

Prepared by the



Dorion Public School
SuperiorGreenstone District School Board
April 1 2021 – March 31, 2022

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; height: 60px; width: 100%;"></div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">One</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [X] No []</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">One</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [X] No []</p>
---	--

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Drinking- Water Systems Regulation O. Reg. 170/03

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office (Municipal)
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method Notice posted at the School

Describe your Drinking Water System

Dorion Public School has been serviced by a single groundwater well supply since the school was built in 1993. The well is a drilled well 6 7/8 inch diameter and completed to a depth of 133 feet, where water is obtained from a sand/gravel aquifer. Maximum flow is 2.0 litres per second.

In order to comply with the minimum treatment requirements contained in the regulation, ultraviolet disinfecting equipment was installed in August 2002.

A professional consulting firm, Engineering North Ltd. of Thunder Bay, was hired by the Board to

Drinking- Water Systems Regulation O. Reg. 170/03

Please provide a brief description and a breakdown of monetary expenses incurred

t(t q o) ren 8 (r1)8 (r o) 1(rfT re t)Q q h W6re SW6rea)..1(rfT re W6re W n B-4 -0311w -2 /871j EMC
Install Repair Replace Description

Drinking- Water Systems Regulation O. Reg. 170/03

Operational testing done under Schedule 7, 8 of Regulation 170/03 during the period covered by this Annual Report.

Number of
Grab
Samples

Drinking- Water Systems Regulation O. Reg. 170/03

	08-30-2021	<0.01	mg/L	No
	11-05-2021	<0.01	mg/L	No
	03-11-2022	<0.01	mg/L	No
Nitrate	05-26-2021	0.139	mg/L	No
	08-30-2021	0.118	mg/L	No
	11-05-2021	0.132	mg/L	No
	03-11-2022	0.131	mg/L	No

Drinking- Water Systems Regulation O. Reg. 170/03

1,4-Dichlorobenzene	1-20-2016	<0.50	... P I >	No
1,2-Dichloroethane	1-20-2016	<0.50	... P I >	No
1,1-Dichloroethylene (vinylidene chloride)	1-20-2016	<0.50	... P I >	No
Dichloromethane(Methylene Chloride)	1-20-2016	<5.0	... P I >	No
2-4 Dichlorophenol	1-20-2016	<0.30	... P I >	No
2,4-Dichlorophenoxy acetic acid (2,4)	1-20-2016	116.2	... P I >	No
Diclofop-methyl	1-20-2016	<0.20	... P I >	No

Dimethoo 627.48 Tm (20)Tj ETTw 11.0.

Drinking- Water Systems Regulation O. Reg. 170/03

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			